

BookCon

Exhibit Booth Construction

- All materials used in exhibit construction and decoration (including without limitation hard wall, canopies, drapes, foam core, tablecloths, burlap, scrim or similar materials) must be fire retardant
- Exhibitors and contractors must have available on site for inspection the appropriate paperwork to demonstrate that these requirements have been met, that either a tag affixed to the item demonstrating that the item has been flame-proofed by the manufacturer or a certificate (valid for one year) demonstrating post-purchase application of fire retardant.
 - Spot checks of compliance with this requirement will be conducted periodically. In addition, field flame tests may be conducted. Appropriate action will be taken if such inspections and tests reveal incidents of non-compliance.